



RAJKOT MUNICIPAL CORPORATION



Dr. Ambedkar Bhavan, Dhebar Road

Fire & Emergency Service

RAJKOT 360 001. Ph.No. 2227222

R.M.C.F.E.S.No.NOC.154.

Date.26.06.2020.

:-: RENEW FIRE NO OBJECTION CERTIFICATE :-:

Reference No.1.R.M.C.F.E.S.NOC.E.No.162, DATE:-24-06-2020.

2.R.M.C.F.B. Old Renew NOC.No.446, DATE:-16-01-2017.

This is to Renew Fire NOC That Owner/ Principal/ Trustee "OXFORD INTERNATIONAL SCHOOL". School Building Floor:-G.F-1ST, 2ND Floor, Stair, Type Of Plan:-Frame Structure, Use Of Building:-Education (Up To Higher Secondary School). R.S.No.614-P1 & 614-P4, Plot No.1, Total Plot Area:-14062.00 Sq.Mt. FSI Used:-8078.52/14062.00=0.574<1.20., Location :-At. Near Ramanathdham Temple, Unvada Road, Gondal-Rajkot Highway, Gondal (Gujarat). Pin-360 311. He Made School Building As per his demand to Renew Fire NOC though Inward No.162, Dated:-24-06-2020, he endorsed that Fire Safety instruments are there in light of above Renew Fire NO Objection Certificate given in favors of the School. Have Complied with BPMC ACT 1949 Building Law & NBC 1984 To 2020 RMC and Verified by Officer Of Fire and emergency services RMC Rajkot On Dated :-25-06-2020.

- (1) Fire extinguisher installed in School premise each Both Side Lobby Floor area ABC Type fire extinguisher Capacity 5 kg No's 01 & Co2 Type fire extinguisher 4.5 kg No's 01 and also Installed in Computer Room, Office, Library, Laboratory, Lab-room area protected with ABC Type fire extinguisher Capacity 5 kg No's 01 & Co2 Type fire extinguisher 4.5 kg No's 01.
- (2) However the following terms & Condition shall be complied with time and reports shall be submitted to concerned authority.
- (3) The School Staff and students shall have to undergo fire prevention Training once in a years by "OXFORD INTERNATIONAL SCHOOL." Fire Service Fire Officials and Record there of shall be Maintained.
- (4) Electric must be proper and that school Not be loose and Taped in Classroom.
- (5) There should not be any Obstacle in Exit and Emergency lights in Stares & Exit Marked by Radium Symbol is Necessary.
- (6) Reserve Water tank Capacity 1,00,000 liters use for Emergency Purpose.



J. J. J. J.

Manager


Oxford International School
Gondal

[Signature]
PRINCIPAL
OXFORD INTERNATIONAL SCHOOL
GONDAL

- (7) These Fire extinguisher shall be Maintained in working order in the valid period this corticated.
- (8) Above must be followed as per Fire Extinguisher ACT/Rules.
- (9) These Fire extinguisher shall be Maintained in working order in the valid period this corticated.
- (10) This Renew Fire N.O.C is Valid Up to 26 June 2021 Then after it should be Renew Again inspection.

Place :- Rajkot.
Date :- 26-06-2020.




Chief Fire Officer
Fire & Emergency Services
Rajkot Municipal Corporation


Manager
Oxford International School
Gondal


PRINCIPAL
OXFORD INTERNATIONAL SCHOOL
GONDAL